



Chapter 2: Energy and demand projections

- 2.1 Overview
- 2.2 Customer consultation
- 2.3 Demand forecast outlook
- 2.4 Zone forecasts
- 2.5 Daily and annual load profiles

2 Energy and demand projections


Key highlights

- This chapter describes the historical energy and demand performance of Powerlink's transmission network and provides forecast data separated by zone.
- The 2016/17 summer in Queensland was hot and long lasting with a new maximum delivered demand recorded at 6:00pm on 18 January, when 8,401MW was delivered from the transmission network.
- Scheduled as generated and native demand records were reached at 5:30pm on 12 February. The scheduled as generated reached 9,369MW and the native demand reached 8,756MW.
- Powerlink develops its energy and demand forecasts using both a top-down econometric model and bottom-up forecasts from the distribution businesses and direct connect customers.
- Based on the medium economic outlook, Queensland's delivered energy consumption and demand is expected to remain relatively flat, with average annual increases of 0.4% and 0.6% per annum over the next 10 years.
- Powerlink is focused on understanding the potential future impacts of emerging technologies so transmission network services are developed in a way valued by customers. For example, future developments in battery storage technology coupled with small-scale solar photovoltaic (PV) could see significant changes to future electricity usage patterns. This could reduce the need to develop transmission services to cover short duration peaks.

2.1 Overview

The 2016/17 summer in Queensland was hot and long lasting with two days of particularly high electricity demand on the transmission network on 18 January and 12 February. A new delivered maximum demand was recorded at 6:00pm on 18 January, when 8,401MW was delivered from the transmission network. Scheduled as generated and native demand records were recorded at 5:30pm on 12 February, with scheduled as generated reaching 9,369MW and native demand reaching 8,756MW. The corresponding delivered demand on 12 February was 8,392MW, slightly lower than 18 January record. The scheduled as generated record of 9,369MW exceeded the previous record of 9,097MW recorded in February 2016. After temperature correction, the 2016/17 summer demand exceeded the 2016 Transmission Annual Planning Report (TAPR) forecast by around 2%.

Figure 2.1 shows observed temperatures for Brisbane during summer 2016/17 compared with long-term averages.

Figure 2.1 Brisbane weather over summer 2016/17

Note:

(1) Based on years 2000 to 2017

Energy delivered from the transmission network for 2016/17 is expected to be within 1% of the 2016 TAPR forecast.

The CSG (coal seam gas) industry continues to ramp up with observed demands close to those forecast in the 2016 TAPR. By 2018/19, CSG demand is forecast to exceed 750MW. No new CSG loads have committed to connect to the transmission network since the publication of 2016 TAPR.

During the 2016/17 summer, Queensland had around 1,700MW of installed rooftop PV capacity. This rate of increase has slowed to around 15MW per month. An important impact of the rooftop PV has been to delay the time of state peak, which now occurs around 5:30pm. As more rooftop PV is installed, future summer maximum demands are likely to occur in the early evening.

The Queensland Government's Solar 150 initiative to support up to 150MW of solar generation in Queensland in collaboration with the Australian Renewable Energy Agency (ARENA) has been a key driver in the number of solar PV farms now committed and under construction in Queensland. The Federal Government's large-scale renewable energy target of 33,000GWh per annum by 2020 is also expected to drive future renewable capacity in the form of solar PV farms seeking to connect to the Queensland transmission and distribution networks over the next two to three years.

Solar PV farms connecting directly to the distribution network will reduce the amount of energy being delivered through the transmission network and accelerate the delay of the state peak from around 5:30pm to an evening peak. No distribution connected solar PV farms were included in the 2016 TAPR. Additional distribution connected solar PV farm capacity has been included further into the 10-year outlook period to align with Australia's obligations under the Paris Agreement on climate change. Further details on interest from potential variable renewable electricity (VRE) proponents is included in Chapter 7.

2 Energy and demand projections

The forecasts presented in this TAPR indicate relatively flat growth for energy, summer maximum demand and winter maximum demand in the first half of the 10-year outlook period, with moderate growth in the latter half of the 10-year outlook period. While there has been significant investment in the resources sector, global price signals for resources such as coal and gas are unlikely to result in further developments in the short-term. Independent economic outlook is that Queensland, on the whole, is still experiencing slow economic growth, however this is expected to return to solid growth for the second half of the forecasting period. The lower Australian dollar has improved growth prospects in areas such as tourism and foreign education while sustained low interest rates are providing a boost in the housing industry. Queensland's population growth has slowed following the resources boom and is expected to increase by around 15% to around 5.6 million over the 10-year forecast period.

The consumer response to electricity prices is expected to have a continued dampening effect on electricity usage. Future developments in battery storage technology coupled with rooftop PV could see significant changes to future electricity usage patterns. In particular, developments in battery storage technology have the potential to flatten electricity usage, reducing the need to develop transmission services to cover short duration peaks and put downward pressure on transmission costs.

Powerlink is committed to understanding the future impacts of emerging technologies so that transmission network services are developed in a way most valued by customers. Driven by this commitment, Powerlink has again hosted a forum in April 2017 to share and build on knowledge related to emerging technologies. As a result, several enhancements were made to the forecasting methodology associated with emerging technologies in this TAPR. Details of Powerlink's forecasting methodology can be found in Appendix B.

The delivered demand forecast in the 2017 TAPR shows an increase compared to the 2016 TAPR. The increase from 2020 is largely due to an expectation that electricity prices will remain flat and then fall and that the Queensland state economy will return to solid growth. Figure 2.2 shows a comparison of the delivered summer maximum demand forecast with the 2016 TAPR, based on a 50% probability of exceedance (PoE) and medium economic outlook.

The delivered energy forecast in the 2017 TAPR shows a reduction compared to the 2016 TAPR. The reduction to 2020 is largely due to the forecast of distribution connected solar PV farms and a forecast reduction in energy by a major transmission connected customer. Figure 2.3 shows a comparison of the delivered energy forecast with the 2016 TAPR, based on the medium economic outlook.

Figure 2.2 Comparison of the medium economic outlook demand forecasts





Figure 2.3 Comparison of the medium economic outlook energy forecasts



2.2 Customer consultation

In accordance with the National Electricity Rules (NER), Powerlink has obtained summer and winter maximum demand forecasts over a 10-year outlook period from Queensland's Distribution Network Service Providers (DNSPs), Energex and Ergon Energy. These connection supply point forecasts are presented in Appendix A. Also in accordance with the NER, Powerlink has obtained summer and winter maximum demand forecasts from other customers that connect directly to the transmission network. These forecasts have been aggregated into demand forecasts for the Queensland region and for 11 geographical zones, defined in Table 2.12 in Section 2.4, using diversity factors observed from historical trends.

2 Energy and demand projections

Energy forecasts for each connection supply point were obtained from Energex, Ergon Energy and other transmission connected customers. These have also been aggregated for the Queensland region and for each of the 11 geographical zones in Queensland.

Powerlink works with Energex, Ergon Energy, Australian Energy Market Operator (AEMO), customer and consumer representatives, and the wider industry to refine its forecasting process and input information. This takes place through ongoing engagement activities and forums such as the Demand and Energy Forecasting Forum and Powerlink Queensland Transmission Network Forum undertaken prior to and shortly after the release of the TAPR.

Powerlink, Energex and Ergon Energy jointly conduct the Queensland Household Energy Survey to improve understanding of consumer behaviours and intentions. This survey provides air conditioning penetration forecasts that feed directly into the demand forecasting process plus comprehensive insights on consumer intentions on electricity usage.

Powerlink's forecasting methodology is described in Appendix B.

Transmission customer forecasts

New large loads

No new large loads have connected or have committed to connect in the outlook period.

Possible new large loads

There are several proposals under development for large mining, metal processing and other industrial loads. These are not yet at a stage that they can be included (either wholly or in part) in the medium economic forecast. These developments, totalling nearly 900MW, are listed in Table 2.1.

Table 2.1 Possible large loads excluded from the medium economic outlook forecast

| Zone | Description | Possible load |
|------------------------|--|---------------|
| North | Further port expansion at Abbot Point | Up to 100MW |
| North | CSG load (Bowen Basin area) | Up to 80MW |
| North and Central West | New coal mining load (Galilee Basin area) | Up to 400MW |
| Surat | CSG load and coal mining projects (Surat Basin area) | Up to 300MW |

2.3 Demand forecast outlook

The following sections outline the Queensland forecasts for energy, summer demand and winter demand.

All forecasts are prepared for three economic outlooks, high, medium and low. Demand forecasts are also prepared to account for seasonal variation. These seasonal variations are referred to as 10% PoE, 50% PoE and 90% PoE forecasts. They represent conditions that would expect to be exceeded once in 10 years, five times in 10 years and nine times in 10 years respectively.

The forecast average annual growth rates for the Queensland region over the next 10 years under low, medium and high economic growth outlooks are shown in Table 2.2. These growth rates refer to transmission delivered quantities as described in Section 2.3.2. For summer and winter maximum demand, growth rates are based on 50% PoE corrected values for 2016/17.

Table 2.2 Average annual growth rate over next 10 years

| | Economic growth outlooks | | |
|---|--------------------------|--------|------|
| | Low | Medium | High |
| Delivered energy | -0.4% | 0.4% | 1.4% |
| Delivered summer maximum demand (50% PoE) | -0.1% | 0.6% | 1.5% |
| Delivered winter maximum demand (50% PoE) | 0.0% | 0.6% | 1.5% |

2.3.1 Future management of maximum demand


The installation of additional rooftop PV systems and distribution connected solar PV farms is expected to delay the current time of the maximum demand from around 5:30pm to an evening peak and reduce the delivered demand and energy during daylight hours. The latter half of the 10-year demand forecast shows some growth in the maximum demand (refer to Figure 2.2). If the trend continues, Powerlink will need to consider if the network needs to be augmented to meet these evening peaks at a future point. However, there is an opportunity for new technology and non-network solutions to deliver cost efficiencies and negate the need to build new transmission assets by assisting in the management of evening maximum demand. The successful integration of non-network solutions has the potential to shift and reduce maximum demand back to daylight hours where demand levels are reduced due to embedded solar generation.

2.3.2 Demand and energy terminology

The reported demand and energy on the network depends on where it is being measured. Individual stakeholders have reasons to measure demand and energy at different points. Figure 2.4 shows the common ways to measure demand and energy, with this terminology used consistently throughout the TAPR.

2 Energy and demand projections

Figure 2.4 Load forecast definitions



Notes:

- (1) Includes Invicta and Koombooloomba
- (2) Depends on Wivenhoe generation
- (3) Includes Yarwun which is non-scheduled
- (4) Barcaldine, Roma, Mackay and Townsville Power Station 66kV component
- (5) Pioneer Mill, Racecourse Mill, Moranbah North, Moranbah, Barcaldine Solar Farm, German Creek, Oaky Creek, Isis Central Sugar Mill, Daandine, Bromelton and Rocky Point
- (6) For a full list of transmission network generators and scheduled and semi-scheduled embedded generators refer to Table 5.1

2.3.3 Energy forecast

Historical Queensland energies are presented in Table 2.3. They are recorded at various levels in the network as defined in Figure 2.4.

Transmission losses are the difference between transmission sent out and transmission delivered energy. Scheduled power station auxiliaries are the difference between scheduled as generated and scheduled sent out energy.

Table 2.3 Historical energy (GWh)

| Year | Scheduled as generated | Scheduled sent out | Native as generated | Native sent out | Transmission sent out | Transmission delivered | Native | Native plus solar PV |
|-------------|------------------------|--------------------|---------------------|-----------------|-----------------------|------------------------|--------|----------------------|
| 2007/08 | 51,337 | 47,660 | 52,268 | 48,711 | 47,177 | 45,653 | 47,188 | 47,188 |
| 2008/09 | 52,591 | 48,831 | 53,638 | 50,008 | 48,351 | 46,907 | 48,563 | 48,580 |
| 2009/10 | 53,150 | 49,360 | 54,419 | 50,753 | 48,490 | 46,925 | 49,187 | 49,263 |
| 2010/11 | 51,381 | 47,804 | 52,429 | 48,976 | 46,866 | 45,240 | 47,350 | 47,531 |
| 2011/12 | 51,147 | 47,724 | 52,206 | 48,920 | 46,980 | 45,394 | 47,334 | 47,813 |
| 2012/13 | 50,711 | 47,368 | 52,045 | 48,702 | 47,259 | 45,651 | 47,090 | 48,129 |
| 2013/14 | 49,686 | 46,575 | 51,029 | 47,918 | 46,560 | 45,145 | 46,503 | 47,894 |
| 2014/15 | 51,855 | 48,402 | 53,349 | 50,047 | 48,332 | 46,780 | 48,495 | 49,952 |
| 2015/16 | 54,238 | 50,599 | 55,752 | 52,223 | 50,573 | 49,094 | 50,744 | 52,546 |
| 2016/17 (I) | 55,593 | 51,808 | 57,213 | 53,562 | 51,745 | 50,190 | 52,007 | 53,861 |

Note:

(I) These projected end of financial year values are based on revenue and statistical metering data until March 2017.

The forecast transmission delivered energy forecasts are presented in Table 2.4 and displayed in Figure 2.5. Forecast native energy forecasts are presented in Table 2.5.

Table 2.4 Forecast annual transmission delivered energy (GWh)

| Year | Low growth outlook | Medium growth outlook | High growth outlook |
|---------|--------------------|-----------------------|---------------------|
| 2017/18 | 49,161 | 49,560 | 50,584 |
| 2018/19 | 48,553 | 49,171 | 51,695 |
| 2019/20 | 48,123 | 48,924 | 51,958 |
| 2020/21 | 48,210 | 49,414 | 52,713 |
| 2021/22 | 48,541 | 50,144 | 53,782 |
| 2022/23 | 48,644 | 50,669 | 54,558 |
| 2023/24 | 48,530 | 51,001 | 55,180 |
| 2024/25 | 48,615 | 51,520 | 56,300 |
| 2025/26 | 48,475 | 51,858 | 57,044 |
| 2026/27 | 48,076 | 52,459 | 57,404 |

2 Energy and demand projections

Figure 2.5 Historical and forecast transmission delivered energy




Table 2.5 Forecast annual native energy (GWh)

| Year | Low growth outlook | Medium growth outlook | High growth outlook |
|---------|--------------------|-----------------------|---------------------|
| 2017/18 | 50,997 | 51,395 | 52,419 |
| 2018/19 | 50,745 | 51,363 | 53,887 |
| 2019/20 | 50,641 | 51,442 | 54,476 |
| 2020/21 | 50,890 | 52,095 | 55,394 |
| 2021/22 | 51,221 | 52,823 | 56,462 |
| 2022/23 | 51,323 | 53,347 | 57,237 |
| 2023/24 | 51,262 | 53,734 | 57,913 |
| 2024/25 | 51,511 | 54,416 | 59,196 |
| 2025/26 | 51,644 | 55,026 | 60,213 |
| 2026/27 | 51,573 | 55,956 | 60,901 |

2.3.4 Summer maximum demand forecast

Historical Queensland summer maximum demands at time of native peak are presented in Table 2.6.

Table 2.6 Historical summer maximum demand (MW)

| Summer | Scheduled as generated | Scheduled sent out | Native as generated | Native sent out | Transmission sent out | Transmission delivered | Native | Native plus solar PV | Native corrected to 50% PoE |
|---------|------------------------|--------------------|---------------------|-----------------|-----------------------|------------------------|--------|----------------------|-----------------------------|
| 2007/08 | 8,082 | 7,603 | 8,178 | 7,713 | 7,425 | 7,281 | 7,569 | 7,569 | 7,893 |
| 2008/09 | 8,677 | 8,135 | 8,767 | 8,239 | 8,017 | 7,849 | 8,070 | 8,078 | 8,318 |
| 2009/10 | 8,891 | 8,427 | 9,053 | 8,603 | 8,292 | 7,951 | 8,321 | 8,355 | 8,364 |
| 2010/11 | 8,836 | 8,299 | 8,895 | 8,374 | 8,020 | 7,797 | 8,152 | 8,282 | 8,187 |
| 2011/12 | 8,707 | 8,236 | 8,769 | 8,319 | 7,983 | 7,723 | 8,059 | 8,367 | 8,101 |
| 2012/13 | 8,453 | 8,008 | 8,691 | 8,245 | 7,920 | 7,588 | 7,913 | 8,410 | 7,952 |
| 2013/14 | 8,365 | 7,947 | 8,531 | 8,114 | 7,780 | 7,498 | 7,831 | 8,378 | 7,731 |
| 2014/15 | 8,809 | 8,398 | 9,000 | 8,589 | 8,311 | 8,019 | 8,326 | 8,512 | 8,084 |
| 2015/16 | 9,094 | 8,668 | 9,272 | 8,848 | 8,580 | 8,271 | 8,539 | 8,783 | 8,369 |
| 2016/17 | 9,369 | 8,886 | 9,541 | 9,062 | 8,698 | 8,392 | 8,756 | 8,899 | 8,666 |

The transmission delivered summer maximum demand forecasts are presented in Table 2.7 and displayed in Figure 2.6. Forecast summer native demand is presented in Table 2.8.

Table 2.7 Forecast summer transmission delivered demand (MW)

| Summer | Low growth outlook | | | Medium growth outlook | | | High growth outlook | | |
|---------|--------------------|---------|---------|-----------------------|---------|---------|---------------------|---------|---------|
| | 90% PoE | 50% PoE | 10% PoE | 90% PoE | 50% PoE | 10% PoE | 90% PoE | 50% PoE | 10% PoE |
| 2017/18 | 7,877 | 8,317 | 8,881 | 7,931 | 8,372 | 8,938 | 8,113 | 8,558 | 9,127 |
| 2018/19 | 7,806 | 8,244 | 8,805 | 7,898 | 8,339 | 8,905 | 8,163 | 8,612 | 9,188 |
| 2019/20 | 7,758 | 8,199 | 8,763 | 7,887 | 8,332 | 8,902 | 8,240 | 8,698 | 9,284 |
| 2020/21 | 7,747 | 8,194 | 8,768 | 7,914 | 8,368 | 8,949 | 8,356 | 8,827 | 9,430 |
| 2021/22 | 7,781 | 8,236 | 8,820 | 8,015 | 8,479 | 9,075 | 8,505 | 8,989 | 9,610 |
| 2022/23 | 7,772 | 8,232 | 8,822 | 8,070 | 8,542 | 9,148 | 8,600 | 9,095 | 9,729 |
| 2023/24 | 7,736 | 8,201 | 8,796 | 8,095 | 8,575 | 9,191 | 8,686 | 9,192 | 9,840 |
| 2024/25 | 7,767 | 8,239 | 8,844 | 8,190 | 8,682 | 9,312 | 8,867 | 9,387 | 10,053 |
| 2025/26 | 7,763 | 8,243 | 8,857 | 8,249 | 8,752 | 9,396 | 9,001 | 9,535 | 10,219 |
| 2026/27 | 7,744 | 8,230 | 8,852 | 8,300 | 8,813 | 9,471 | 9,103 | 9,650 | 10,351 |

2 Energy and demand projections

Figure 2.6 Historical and forecast transmission delivered summer demand




Table 2.8 Forecast summer native demand (MW)

| Summer | Low growth outlook | | | Medium growth outlook | | | High growth outlook | | |
|---------|--------------------|---------|---------|-----------------------|---------|---------|---------------------|---------|---------|
| | 90% PoE | 50% PoE | 10% PoE | 90% PoE | 50% PoE | 10% PoE | 90% PoE | 50% PoE | 10% PoE |
| 2017/18 | 8,203 | 8,643 | 9,207 | 8,256 | 8,698 | 9,263 | 8,439 | 8,883 | 9,452 |
| 2018/19 | 8,131 | 8,570 | 9,131 | 8,224 | 8,665 | 9,230 | 8,488 | 8,938 | 9,513 |
| 2019/20 | 8,084 | 8,524 | 9,089 | 8,213 | 8,658 | 9,227 | 8,566 | 9,024 | 9,610 |
| 2020/21 | 8,072 | 8,520 | 9,094 | 8,239 | 8,693 | 9,275 | 8,681 | 9,152 | 9,756 |
| 2021/22 | 8,107 | 8,562 | 9,145 | 8,340 | 8,805 | 9,400 | 8,830 | 9,315 | 9,935 |
| 2022/23 | 8,098 | 8,558 | 9,147 | 8,396 | 8,868 | 9,473 | 8,925 | 9,421 | 10,055 |
| 2023/24 | 8,062 | 8,527 | 9,122 | 8,420 | 8,901 | 9,516 | 9,012 | 9,518 | 10,166 |
| 2024/25 | 8,092 | 8,565 | 9,170 | 8,516 | 9,008 | 9,638 | 9,192 | 9,712 | 10,379 |
| 2025/26 | 8,089 | 8,569 | 9,183 | 8,575 | 9,077 | 9,722 | 9,327 | 9,861 | 10,545 |
| 2026/27 | 8,070 | 8,556 | 9,178 | 8,626 | 9,139 | 9,797 | 9,429 | 9,976 | 10,677 |

2.3.5 Winter maximum demand forecast

Historical Queensland winter maximum demands at time of native peak are presented in Table 2.9. As winter demand normally peaks after sunset, solar PV has no impact on winter maximum demand.

Table 2.9 Historical winter maximum demand (MW)

| Winter | Scheduled as generated | Scheduled sent out | Native as generated | Native sent out | Transmission sent out | Transmission delivered | Native | Native plus solar PV | Native corrected to 50% PoE |
|--------|------------------------|--------------------|---------------------|-----------------|-----------------------|------------------------|--------|----------------------|-----------------------------|
| 2007 | 7,837 | 7,416 | 7,893 | 7,481 | 7,298 | 7,166 | 7,350 | 7,350 | 7,026 |
| 2008 | 8,197 | 7,758 | 8,283 | 7,858 | 7,612 | 7,420 | 7,665 | 7,665 | 7,237 |
| 2009 | 7,655 | 7,158 | 7,756 | 7,275 | 7,032 | 6,961 | 7,205 | 7,205 | 7,295 |
| 2010 | 7,313 | 6,885 | 7,608 | 7,194 | 6,795 | 6,534 | 6,933 | 6,933 | 6,942 |
| 2011 | 7,640 | 7,207 | 7,816 | 7,400 | 7,093 | 6,878 | 7,185 | 7,185 | 6,998 |
| 2012 | 7,490 | 7,081 | 7,520 | 7,128 | 6,955 | 6,761 | 6,934 | 6,934 | 6,908 |
| 2013 | 7,150 | 6,753 | 7,345 | 6,947 | 6,699 | 6,521 | 6,769 | 6,769 | 6,983 |
| 2014 | 7,288 | 6,895 | 7,470 | 7,077 | 6,854 | 6,647 | 6,881 | 6,881 | 6,999 |
| 2015 | 7,816 | 7,369 | 8,027 | 7,620 | 7,334 | 7,126 | 7,411 | 7,412 | 7,301 |
| 2016 | 8,020 | 7,513 | 8,191 | 7,686 | 7,439 | 7,207 | 7,454 | 7,454 | 7,480 |

The transmission delivered winter maximum demand forecasts are presented in Table 2.10 and displayed in Figure 2.7. Forecast winter native demand is presented in Table 2.11.

Table 2.10 Forecast winter transmission delivered demand (MW)

| Winter | Low growth outlook | | | Medium growth outlook | | | High growth outlook | | |
|--------|--------------------|---------|---------|-----------------------|---------|---------|---------------------|---------|---------|
| | 90% PoE | 50% PoE | 10% PoE | 90% PoE | 50% PoE | 10% PoE | 90% PoE | 50% PoE | 10% PoE |
| 2017 | 7,077 | 7,263 | 7,534 | 7,118 | 7,304 | 7,575 | 7,176 | 7,363 | 7,635 |
| 2018 | 7,048 | 7,232 | 7,500 | 7,117 | 7,302 | 7,571 | 7,373 | 7,561 | 7,834 |
| 2019 | 7,039 | 7,224 | 7,493 | 7,131 | 7,317 | 7,587 | 7,452 | 7,642 | 7,920 |
| 2020 | 7,043 | 7,231 | 7,505 | 7,159 | 7,348 | 7,624 | 7,557 | 7,753 | 8,037 |
| 2021 | 7,072 | 7,263 | 7,541 | 7,241 | 7,434 | 7,716 | 7,664 | 7,864 | 8,156 |
| 2022 | 7,083 | 7,276 | 7,558 | 7,303 | 7,500 | 7,786 | 7,746 | 7,951 | 8,248 |
| 2023 | 7,060 | 7,256 | 7,540 | 7,327 | 7,527 | 7,817 | 7,812 | 8,020 | 8,324 |
| 2024 | 7,079 | 7,278 | 7,567 | 7,395 | 7,600 | 7,898 | 7,940 | 8,155 | 8,466 |
| 2025 | 7,095 | 7,297 | 7,592 | 7,461 | 7,670 | 7,975 | 8,070 | 8,290 | 8,610 |
| 2026 | 7,058 | 7,263 | 7,562 | 7,480 | 7,694 | 8,005 | 8,130 | 8,354 | 8,682 |

2 Energy and demand projections

Figure 2.7 Historical and forecast winter transmission delivered demand




Table 2.11 Forecast winter native demand (MW)

| Winter | Low growth outlook | | | Medium growth outlook | | | High growth outlook | | |
|--------|--------------------|---------|---------|-----------------------|---------|---------|---------------------|---------|---------|
| | 90% PoE | 50% PoE | 10% PoE | 90% PoE | 50% PoE | 10% PoE | 90% PoE | 50% PoE | 10% PoE |
| 2017 | 7,322 | 7,508 | 7,778 | 7,363 | 7,549 | 7,820 | 7,420 | 7,607 | 7,880 |
| 2018 | 7,292 | 7,477 | 7,745 | 7,361 | 7,546 | 7,816 | 7,617 | 7,805 | 8,079 |
| 2019 | 7,284 | 7,468 | 7,737 | 7,376 | 7,562 | 7,832 | 7,696 | 7,887 | 8,164 |
| 2020 | 7,288 | 7,476 | 7,749 | 7,404 | 7,593 | 7,868 | 7,802 | 7,997 | 8,282 |
| 2021 | 7,317 | 7,508 | 7,786 | 7,486 | 7,679 | 7,960 | 7,908 | 8,109 | 8,401 |
| 2022 | 7,328 | 7,521 | 7,802 | 7,548 | 7,744 | 8,030 | 7,991 | 8,195 | 8,493 |
| 2023 | 7,305 | 7,500 | 7,785 | 7,572 | 7,771 | 8,062 | 8,056 | 8,265 | 8,568 |
| 2024 | 7,323 | 7,522 | 7,812 | 7,640 | 7,844 | 8,142 | 8,185 | 8,399 | 8,711 |
| 2025 | 7,339 | 7,542 | 7,836 | 7,705 | 7,915 | 8,220 | 8,315 | 8,534 | 8,854 |
| 2026 | 7,304 | 7,509 | 7,808 | 7,726 | 7,940 | 8,251 | 8,375 | 8,600 | 8,927 |

2.4 Zone forecasts

The 11 geographical zones referred to throughout this TAPR are defined in Table 2.12 and are shown in the diagrams in Appendix C. In the 2008 Annual Planning Report (APR) Powerlink split the South West zone into Bulli and South West zones, and in the 2014 TAPR Powerlink split the South West zone into Surat and South West zones.

Table 2.12 Zone definitions

| Zone | Area covered |
|--------------|---|
| Far North | North of Tully, including Chalumbin |
| Ross | North of Proserpine and Collinsville North, excluding the Far North zone |
| North | North of Broadsound and Dysart, excluding the Far North and Ross zones |
| Central West | South of Nebo, Peak Downs and Mt McLaren, and north of Gin Gin, but excluding the Gladstone zone |
| Gladstone | South of Raglan, north of Gin Gin and east of Calvale |
| Wide Bay | Gin Gin, Teebar Creek and Woolooga 275kV substation loads, excluding Gympie |
| Surat | West of Western Downs and south of Moura, excluding the Bulli zone |
| Bulli | Goondiwindi (Waggamba) load and the 275/330kV network south of Kogan Creek and west of Millmerran |
| South West | Tarong and Middle Ridge load areas west of Postmans Ridge, excluding the Bulli and Surat zones |
| Moreton | South of Woolooga and east of Middle Ridge, but excluding the Gold Coast zone |
| Gold Coast | East of Greenbank, south of Coomera to the Queensland/New South Wales border |

Each zone normally experiences its own maximum demand, which is usually greater than that shown in tables 2.16 to 2.19.

Table 2.13 shows the average ratios of forecast zone maximum transmission delivered demand to zone transmission delivered demand at the time of forecast Queensland region maximum demand. These values can be used to multiply demands in tables 2.16 and 2.18 to estimate each zone's individual maximum transmission delivered demand, the time of which is not necessarily coincident with the time of Queensland region maximum transmission delivered demand. The ratios are based on historical trends.

Table 2.13 Average ratios of zone maximum delivered demand to zone delivered demand at time of Queensland region maximum demand

| Zone | Winter | Summer |
|--------------|--------|--------|
| Far North | 1.19 | 1.19 |
| Ross | 1.50 | 1.60 |
| North | 1.15 | 1.18 |
| Central West | 1.10 | 1.18 |
| Gladstone | 1.03 | 1.05 |
| Wide Bay | 1.03 | 1.13 |
| Surat | 1.13 | 1.14 |
| Bulli | 1.15 | 1.30 |
| South West | 1.04 | 1.19 |
| Moreton | 1.01 | 1.01 |
| Gold Coast | 1.02 | 1.01 |

2 Energy and demand projections

Tables 2.14 and 2.15 show the forecast of transmission delivered energy and native energy for the medium economic outlook for each of the 11 zones in the Queensland region.

Table 2.14 Annual transmission delivered energy (GWh) by zone

| Year | Far North | Ross | North | Central West | Gladstone | Wide Bay | Surat | Bulli | South West | Moreton | Gold Coast | Total |
|------------------|-----------|-------|-------|--------------|-----------|----------|-------|-------|------------|---------|------------|--------|
| Actuals | | | | | | | | | | | | |
| 2007/08 | 1,818 | 2,719 | 2,728 | 3,165 | 10,058 | 1,399 | | 87 | 1,712 | 18,684 | 3,283 | 45,653 |
| 2008/09 | 1,851 | 2,772 | 2,779 | 3,191 | 10,076 | 1,430 | | 94 | 1,774 | 19,532 | 3,408 | 46,907 |
| 2009/10 | 1,836 | 2,849 | 2,719 | 3,300 | 10,173 | 1,427 | | 84 | 1,442 | 19,619 | 3,476 | 46,925 |
| 2010/11 | 1,810 | 2,791 | 2,590 | 3,152 | 10,118 | 1,308 | | 95 | 1,082 | 18,886 | 3,408 | 45,240 |
| 2011/12 | 1,792 | 2,723 | 2,611 | 3,463 | 10,286 | 1,323 | | 105 | 1,196 | 18,629 | 3,266 | 45,394 |
| 2012/13 | 1,722 | 2,693 | 2,732 | 3,414 | 10,507 | 1,267 | | 103 | 1,746 | 18,232 | 3,235 | 45,651 |
| 2013/14 | 1,658 | 2,826 | 2,828 | 3,564 | 10,293 | 1,321 | 338 | 146 | 1,304 | 17,782 | 3,085 | 45,145 |
| 2014/15 | 1,697 | 2,977 | 2,884 | 3,414 | 10,660 | 1,266 | 821 | 647 | 1,224 | 18,049 | 3,141 | 46,780 |
| 2015/16 | 1,724 | 2,944 | 2,876 | 3,327 | 10,721 | 1,272 | 2,633 | 1,290 | 1,224 | 17,944 | 3,139 | 49,094 |
| 2016/17 | 1,738 | 2,715 | 2,677 | 3,130 | 10,219 | 1,326 | 4,049 | 1,521 | 1,312 | 18,315 | 3,188 | 50,190 |
| Forecasts | | | | | | | | | | | | |
| 2017/18 | 1,683 | 2,818 | 2,908 | 3,352 | 9,489 | 1,278 | 4,267 | 1,518 | 1,178 | 17,715 | 3,354 | 49,560 |
| 2018/19 | 1,647 | 2,736 | 2,850 | 3,217 | 9,490 | 1,209 | 4,428 | 1,566 | 1,132 | 17,562 | 3,334 | 49,171 |
| 2019/20 | 1,631 | 2,720 | 2,871 | 3,054 | 9,499 | 1,057 | 4,515 | 1,596 | 1,117 | 17,529 | 3,335 | 48,924 |
| 2020/21 | 1,655 | 2,766 | 2,915 | 3,045 | 9,528 | 1,001 | 4,542 | 1,608 | 1,130 | 17,831 | 3,393 | 49,414 |
| 2021/22 | 1,678 | 2,814 | 2,968 | 3,103 | 9,549 | 1,034 | 4,662 | 1,598 | 1,144 | 18,142 | 3,452 | 50,144 |
| 2022/23 | 1,695 | 2,854 | 3,064 | 3,147 | 9,567 | 1,061 | 4,681 | 1,569 | 1,152 | 18,382 | 3,497 | 50,669 |
| 2023/24 | 1,707 | 2,889 | 3,152 | 3,156 | 9,584 | 1,085 | 4,680 | 1,497 | 1,129 | 18,587 | 3,535 | 51,001 |
| 2024/25 | 1,741 | 2,951 | 3,172 | 3,207 | 9,610 | 1,127 | 4,624 | 1,413 | 1,061 | 19,000 | 3,614 | 51,520 |
| 2025/26 | 1,777 | 3,017 | 3,068 | 3,289 | 9,639 | 1,122 | 4,463 | 1,326 | 1,022 | 19,438 | 3,697 | 51,858 |
| 2026/27 | 1,782 | 3,061 | 2,993 | 3,420 | 9,679 | 1,138 | 4,303 | 1,077 | 1,060 | 20,120 | 3,826 | 52,459 |

Table 2.15 Annual native energy (GWh) by zone

| Year | Far North | Ross | North | Central West | Gladstone | Wide Bay | Surat | Bulli | South West | Moreton | Gold Coast | Total |
|------------------|-----------|-------|-------|--------------|-----------|----------|-------|-------|------------|---------|------------|--------|
| Actuals | | | | | | | | | | | | |
| 2007/08 | 1,818 | 3,371 | 2,771 | 3,528 | 10,058 | 1,413 | | 87 | 2,039 | 18,819 | 3,283 | 47,188 |
| 2008/09 | 1,851 | 3,336 | 2,950 | 3,481 | 10,076 | 1,437 | | 94 | 2,265 | 19,665 | 3,408 | 48,563 |
| 2009/10 | 1,836 | 3,507 | 3,070 | 3,635 | 10,173 | 1,447 | | 84 | 2,193 | 19,766 | 3,476 | 49,187 |
| 2010/11 | 1,810 | 3,220 | 2,879 | 3,500 | 10,118 | 1,328 | | 95 | 2,013 | 18,979 | 3,408 | 47,350 |
| 2011/12 | 1,792 | 3,217 | 2,901 | 3,710 | 10,286 | 1,348 | | 105 | 2,014 | 18,695 | 3,266 | 47,334 |
| 2012/13 | 1,722 | 3,080 | 3,064 | 3,767 | 10,507 | 1,292 | | 103 | 1,988 | 18,332 | 3,235 | 47,090 |
| 2013/14 | 1,658 | 3,067 | 3,154 | 3,944 | 10,293 | 1,339 | 402 | 146 | 1,536 | 17,879 | 3,085 | 46,503 |
| 2014/15 | 1,697 | 3,163 | 3,434 | 3,841 | 10,660 | 1,285 | 1,022 | 647 | 1,468 | 18,137 | 3,141 | 48,495 |
| 2015/16 | 1,724 | 3,141 | 3,444 | 3,767 | 10,721 | 1,293 | 2,739 | 1,290 | 1,475 | 18,011 | 3,139 | 50,744 |
| 2016/17 | 1,738 | 3,066 | 3,364 | 3,569 | 10,219 | 1,354 | 4,096 | 1,521 | 1,551 | 18,341 | 3,188 | 52,007 |
| Forecasts | | | | | | | | | | | | |
| 2017/18 | 1,697 | 3,135 | 3,574 | 3,731 | 9,489 | 1,298 | 4,352 | 1,518 | 1,457 | 17,789 | 3,355 | 51,395 |
| 2018/19 | 1,675 | 3,127 | 3,562 | 3,702 | 9,491 | 1,295 | 4,513 | 1,566 | 1,438 | 17,659 | 3,335 | 51,363 |
| 2019/20 | 1,660 | 3,127 | 3,583 | 3,685 | 9,499 | 1,297 | 4,612 | 1,596 | 1,424 | 17,624 | 3,335 | 51,442 |
| 2020/21 | 1,683 | 3,174 | 3,627 | 3,742 | 9,528 | 1,328 | 4,651 | 1,608 | 1,437 | 17,924 | 3,393 | 52,095 |
| 2021/22 | 1,707 | 3,222 | 3,680 | 3,800 | 9,549 | 1,361 | 4,771 | 1,598 | 1,450 | 18,234 | 3,451 | 52,823 |
| 2022/23 | 1,723 | 3,262 | 3,776 | 3,843 | 9,567 | 1,388 | 4,790 | 1,569 | 1,458 | 18,474 | 3,497 | 53,347 |
| 2023/24 | 1,736 | 3,297 | 3,864 | 3,880 | 9,584 | 1,412 | 4,789 | 1,497 | 1,463 | 18,677 | 3,535 | 53,734 |
| 2024/25 | 1,769 | 3,359 | 3,933 | 3,958 | 9,610 | 1,454 | 4,733 | 1,413 | 1,483 | 19,090 | 3,614 | 54,416 |
| 2025/26 | 1,805 | 3,425 | 3,993 | 4,041 | 9,638 | 1,498 | 4,573 | 1,326 | 1,504 | 19,526 | 3,697 | 55,026 |
| 2026/27 | 1,865 | 3,524 | 4,087 | 4,171 | 9,679 | 1,564 | 4,413 | 1,077 | 1,542 | 20,208 | 3,826 | 55,956 |

2 Energy and demand projections

Tables 2.16 and 2.17 show the forecast of transmission delivered winter maximum demand and native winter maximum demand for each of the 11 zones in the Queensland region. It is based on the medium economic outlook and average winter weather.

Table 2.16 State winter maximum transmission delivered demand (MW) by zone

| Winter | Far North | Ross | North | Central West | Gladstone | Wide Bay | Surat | Bulli | South West | Moreton | Gold Coast | Total |
|------------------|-----------|------|-------|--------------|-----------|----------|-------|-------|------------|---------|------------|-------|
| Actuals | | | | | | | | | | | | |
| 2007 | 219 | 309 | 286 | 442 | 1,165 | 297 | | | 410 | 3,451 | 587 | 7,166 |
| 2008 | 216 | 285 | 361 | 432 | 1,161 | 253 | | 17 | 374 | 3,655 | 666 | 7,420 |
| 2009 | 210 | 342 | 328 | 416 | 1,125 | 218 | | 19 | 341 | 3,361 | 601 | 6,961 |
| 2010 | 227 | 192 | 325 | 393 | 1,174 | 179 | | 18 | 269 | 3,173 | 584 | 6,534 |
| 2011 | 230 | 216 | 317 | 432 | 1,155 | 222 | | 22 | 376 | 3,303 | 605 | 6,878 |
| 2012 | 214 | 212 | 326 | 426 | 1,201 | 215 | | 20 | 346 | 3,207 | 594 | 6,761 |
| 2013 | 195 | 249 | 348 | 418 | 1,200 | 190 | 23 | 17 | 263 | 3,039 | 579 | 6,521 |
| 2014 | 226 | 346 | 359 | 463 | 1,200 | 204 | 16 | 51 | 257 | 2,974 | 551 | 6,647 |
| 2015 | 192 | 289 | 332 | 429 | 1,249 | 203 | 172 | 137 | 258 | 3,268 | 597 | 7,126 |
| 2016 | 216 | 278 | 341 | 451 | 1,229 | 193 | 467 | 193 | 280 | 3,009 | 550 | 7,207 |
| Forecasts | | | | | | | | | | | | |
| 2017 | 202 | 283 | 388 | 388 | 1,062 | 208 | 476 | 195 | 252 | 3,274 | 576 | 7,304 |
| 2018 | 203 | 278 | 398 | 380 | 1,064 | 204 | 504 | 202 | 246 | 3,251 | 572 | 7,302 |
| 2019 | 203 | 278 | 401 | 380 | 1,063 | 203 | 511 | 205 | 247 | 3,258 | 568 | 7,317 |
| 2020 | 206 | 278 | 406 | 387 | 1,064 | 202 | 509 | 195 | 247 | 3,283 | 571 | 7,348 |
| 2021 | 212 | 280 | 414 | 393 | 1,065 | 203 | 521 | 198 | 249 | 3,324 | 575 | 7,434 |
| 2022 | 211 | 278 | 444 | 402 | 1,066 | 201 | 531 | 198 | 246 | 3,346 | 577 | 7,500 |
| 2023 | 212 | 266 | 462 | 404 | 1,066 | 201 | 527 | 196 | 247 | 3,366 | 580 | 7,527 |
| 2024 | 216 | 270 | 468 | 410 | 1,068 | 204 | 517 | 188 | 251 | 3,418 | 590 | 7,600 |
| 2025 | 219 | 274 | 474 | 416 | 1,070 | 206 | 516 | 180 | 254 | 3,464 | 597 | 7,670 |
| 2026 | 221 | 276 | 477 | 422 | 1,071 | 208 | 496 | 169 | 256 | 3,497 | 601 | 7,694 |

Table 2.17 State winter maximum native demand (MW) by zone

| Winter | Far North | Ross | North | Central West | Gladstone | Wide Bay | Surat | Bulli | South West | Moreton | Gold Coast | Total |
|------------------|-----------|------|-------|--------------|-----------|----------|-------|-------|------------|---------|------------|-------|
| Actuals | | | | | | | | | | | | |
| 2007 | 219 | 309 | 292 | 520 | 1,165 | 297 | | | 485 | 3,476 | 587 | 7,350 |
| 2008 | 216 | 362 | 365 | 470 | 1,161 | 253 | | 17 | 479 | 3,676 | 666 | 7,665 |
| 2009 | 210 | 425 | 372 | 466 | 1,125 | 218 | | 19 | 407 | 3,362 | 601 | 7,205 |
| 2010 | 227 | 319 | 363 | 484 | 1,174 | 186 | | 18 | 380 | 3,198 | 584 | 6,933 |
| 2011 | 230 | 339 | 360 | 520 | 1,155 | 222 | | 22 | 428 | 3,304 | 605 | 7,185 |
| 2012 | 214 | 289 | 360 | 460 | 1,201 | 215 | | 20 | 375 | 3,206 | 594 | 6,934 |
| 2013 | 195 | 291 | 374 | 499 | 1,200 | 195 | 89 | 17 | 290 | 3,040 | 579 | 6,769 |
| 2014 | 226 | 369 | 420 | 509 | 1,200 | 204 | 90 | 51 | 286 | 2,975 | 551 | 6,881 |
| 2015 | 192 | 334 | 404 | 518 | 1,249 | 203 | 208 | 137 | 288 | 3,281 | 597 | 7,411 |
| 2016 | 216 | 358 | 419 | 504 | 1,229 | 200 | 467 | 193 | 310 | 3,008 | 550 | 7,454 |
| Forecasts | | | | | | | | | | | | |
| 2017 | 202 | 336 | 450 | 449 | 1,063 | 210 | 511 | 195 | 281 | 3,276 | 576 | 7,549 |
| 2018 | 203 | 332 | 460 | 440 | 1,063 | 206 | 539 | 202 | 275 | 3,254 | 572 | 7,546 |
| 2019 | 203 | 332 | 462 | 441 | 1,064 | 205 | 547 | 205 | 275 | 3,260 | 568 | 7,562 |
| 2020 | 206 | 332 | 467 | 447 | 1,064 | 205 | 544 | 195 | 276 | 3,286 | 571 | 7,593 |
| 2021 | 212 | 333 | 475 | 454 | 1,066 | 206 | 557 | 198 | 277 | 3,326 | 575 | 7,679 |
| 2022 | 211 | 331 | 505 | 463 | 1,066 | 203 | 566 | 198 | 275 | 3,349 | 577 | 7,744 |
| 2023 | 212 | 319 | 524 | 465 | 1,066 | 204 | 562 | 196 | 275 | 3,368 | 580 | 7,771 |
| 2024 | 216 | 323 | 530 | 471 | 1,068 | 206 | 552 | 188 | 280 | 3,420 | 590 | 7,844 |
| 2025 | 219 | 327 | 535 | 477 | 1,070 | 209 | 551 | 181 | 283 | 3,466 | 597 | 7,915 |
| 2026 | 221 | 329 | 539 | 483 | 1,071 | 210 | 531 | 170 | 285 | 3,500 | 601 | 7,940 |

2 Energy and demand projections

Tables 2.18 and 2.19 show the forecast of transmission delivered summer maximum demand and native summer maximum demand for each of the 11 zones in the Queensland region. It is based on the medium economic outlook and average summer weather.

Table 2.18 State summer maximum transmission delivered demand (MW) by zone

| Summer | Far North | Ross | North | Central West | Gladstone | Wide Bay | Surat | Bulli | South West | Moreton | Gold Coast | Total |
|------------------|-----------|------|-------|--------------|-----------|----------|-------|-------|------------|---------|------------|-------|
| Actuals | | | | | | | | | | | | |
| 2007/08 | 292 | 296 | 386 | 476 | 1,193 | 243 | | 15 | 314 | 3,466 | 600 | 7,281 |
| 2008/09 | 280 | 350 | 317 | 459 | 1,178 | 278 | | 19 | 367 | 3,934 | 667 | 7,849 |
| 2009/10 | 317 | 394 | 415 | 505 | 1,176 | 268 | | 11 | 211 | 3,919 | 735 | 7,951 |
| 2010/11 | 306 | 339 | 371 | 469 | 1,172 | 274 | | 18 | 175 | 3,990 | 683 | 7,797 |
| 2011/12 | 296 | 376 | 405 | 525 | 1,191 | 249 | | 18 | 217 | 3,788 | 658 | 7,723 |
| 2012/13 | 277 | 303 | 384 | 536 | 1,213 | 232 | | 14 | 241 | 3,754 | 634 | 7,588 |
| 2013/14 | 271 | 318 | 353 | 493 | 1,147 | 260 | 30 | 21 | 291 | 3,711 | 603 | 7,498 |
| 2014/15 | 278 | 381 | 399 | 466 | 1,254 | 263 | 130 | 81 | 227 | 3,848 | 692 | 8,019 |
| 2015/16 | 308 | 392 | 412 | 443 | 1,189 | 214 | 313 | 155 | 231 | 3,953 | 661 | 8,271 |
| 2016/17 | 269 | 291 | 392 | 476 | 1,088 | 276 | 447 | 175 | 309 | 3,957 | 712 | 8,392 |
| Forecasts | | | | | | | | | | | | |
| 2017/18 | 323 | 374 | 411 | 463 | 1,038 | 208 | 471 | 179 | 255 | 3,971 | 679 | 8,372 |
| 2018/19 | 322 | 371 | 407 | 458 | 1,041 | 205 | 486 | 181 | 253 | 3,947 | 668 | 8,339 |
| 2019/20 | 322 | 368 | 407 | 463 | 1,040 | 204 | 489 | 178 | 252 | 3,944 | 665 | 8,332 |
| 2020/21 | 327 | 368 | 417 | 463 | 1,040 | 203 | 488 | 174 | 252 | 3,968 | 668 | 8,368 |
| 2021/22 | 331 | 371 | 422 | 479 | 1,043 | 204 | 504 | 174 | 253 | 4,022 | 676 | 8,479 |
| 2022/23 | 333 | 358 | 453 | 486 | 1,045 | 204 | 507 | 173 | 254 | 4,049 | 680 | 8,542 |
| 2023/24 | 335 | 358 | 467 | 485 | 1,045 | 204 | 503 | 171 | 253 | 4,070 | 684 | 8,575 |
| 2024/25 | 341 | 365 | 474 | 493 | 1,047 | 207 | 503 | 163 | 258 | 4,137 | 694 | 8,682 |
| 2025/26 | 347 | 371 | 479 | 499 | 1,049 | 209 | 489 | 155 | 261 | 4,192 | 701 | 8,752 |
| 2026/27 | 353 | 376 | 482 | 504 | 1,053 | 211 | 474 | 150 | 263 | 4,237 | 710 | 8,813 |

Table 2.19 State summer maximum native demand (MW) by zone

| Summer | Far North | Ross | North | Central West | Gladstone | Wide Bay | Surat | Bulli | South West | Moreton | Gold Coast | Total |
|------------------|-----------|------|-------|--------------|-----------|----------|-------|-------|------------|---------|------------|-------|
| Actuals | | | | | | | | | | | | |
| 2007/08 | 292 | 404 | 390 | 533 | 1,193 | 243 | | 15 | 387 | 3,512 | 600 | 7,569 |
| 2008/09 | 280 | 423 | 331 | 510 | 1,178 | 278 | | 19 | 421 | 3,963 | 667 | 8,070 |
| 2009/10 | 317 | 500 | 453 | 539 | 1,176 | 268 | | 11 | 361 | 3,961 | 735 | 8,321 |
| 2010/11 | 306 | 412 | 408 | 551 | 1,172 | 274 | | 18 | 337 | 3,991 | 683 | 8,152 |
| 2011/12 | 296 | 449 | 434 | 598 | 1,191 | 249 | | 18 | 378 | 3,788 | 658 | 8,059 |
| 2012/13 | 277 | 417 | 422 | 568 | 1,213 | 241 | | 14 | 328 | 3,799 | 634 | 7,913 |
| 2013/14 | 271 | 423 | 386 | 561 | 1,147 | 260 | 88 | 21 | 316 | 3,755 | 603 | 7,831 |
| 2014/15 | 278 | 399 | 479 | 548 | 1,254 | 263 | 189 | 81 | 254 | 3,889 | 692 | 8,326 |
| 2015/16 | 308 | 423 | 491 | 519 | 1,189 | 214 | 370 | 155 | 257 | 3,952 | 661 | 8,539 |
| 2016/17 | 269 | 364 | 512 | 559 | 1,088 | 276 | 498 | 175 | 329 | 3,974 | 712 | 8,756 |
| Forecasts | | | | | | | | | | | | |
| 2017/18 | 324 | 449 | 490 | 524 | 1,038 | 210 | 532 | 179 | 281 | 3,992 | 679 | 8,698 |
| 2018/19 | 322 | 446 | 486 | 519 | 1,040 | 208 | 547 | 181 | 279 | 3,969 | 668 | 8,665 |
| 2019/20 | 322 | 443 | 486 | 524 | 1,040 | 206 | 550 | 179 | 278 | 3,965 | 665 | 8,658 |
| 2020/21 | 327 | 443 | 497 | 524 | 1,040 | 205 | 548 | 174 | 278 | 3,989 | 668 | 8,693 |
| 2021/22 | 331 | 447 | 501 | 541 | 1,043 | 206 | 564 | 174 | 279 | 4,044 | 675 | 8,805 |
| 2022/23 | 333 | 433 | 532 | 547 | 1,045 | 207 | 568 | 173 | 280 | 4,070 | 680 | 8,868 |
| 2023/24 | 335 | 434 | 546 | 546 | 1,045 | 206 | 563 | 171 | 279 | 4,091 | 685 | 8,901 |
| 2024/25 | 341 | 441 | 553 | 554 | 1,047 | 209 | 564 | 163 | 284 | 4,158 | 694 | 9,008 |
| 2025/26 | 347 | 446 | 558 | 560 | 1,049 | 211 | 550 | 155 | 287 | 4,213 | 701 | 9,077 |
| 2026/27 | 353 | 452 | 561 | 566 | 1,052 | 213 | 534 | 149 | 290 | 4,259 | 710 | 9,139 |

2 Energy and demand projections

2.5 Daily and annual load profiles

The daily load profiles (transmission delivered) for the Queensland region on the days of 2016 winter and 2016/17 summer maximum native demands are shown in Figure 2.8.

The annual cumulative load duration characteristic for the Queensland region transmission delivered demand is shown in Figure 2.9.

Figure 2.8 Daily load profile of winter 2016 and summer 2016/17 maximum native demand days




Figure 2.9 Normalised cumulative transmission delivered load duration from 1 April 2016 to 31 March 2017

